



VILL - KUTAIL, Distt.Karnal-132001 School Code:1882

Email id - gssskutail@gmail.com

Website - pmshrikutail.com

Ref.no. 0391

Dated 29/04/2024

Undertaking

It is certified that the school has applied for Fire N.O.C. It will take some time. After getting completed the N.O.C. It will be produced to the cbse office within three months.

Jringl Principal PM SHRI G.S.S School Kutal (1880) Karnal

हरियाणा सरकार

Memo No.:- FSk/2024/ 330 Sub

Dated:- 11-04-24

Approval of fire fighting scheme from the fire safety point of view of the Group-B Educational Building meas. 28338.19 SQM Sqm. Mtrs. M/S P.M Shri Govt Senior Secondary School Situated in the Village Kutail KARNAL,

M/S P.M Shri Govt Senior Secondary School has submitted the subject cited case for Approval of Fire Fighting Scheme from fire safety point of view of the Group-B Educational Building. 28338.19 Sqm Mtrs. Situated at Village Kutail KARNAL, through transaction ID 100602423000077 Dated 04/04/2024. The office has examined the Fire Fighting Scheme in the drawing of above said building and found that the building is an Educational Building Group-B. Fire fighting scheme shown in the Building Plans are found as per provision of Part-IV of National Building Code of India, 1983 revised from time to time and Haryana Fire & Emergency Services Act, 2022. The fire system designed Educational Building as per Part- IV of NBC 2016,

Building Details :-

- 1. Name of Building:-
- 2. Address of building-:-
- 3. Plot Area:-
- 4. Type of Occupancy:-
- 5. Permissible Height:-

M/S P.M Shri Govt Senior Secondary School Village Kutail KARNAL. 28338.19 Sqm . Mtrs. **Group-B Educational Building** 18 m

6. Basement Detail:-

Nil	ime	Basement Lev	vel Basen	nent Area		Remarks	
Nil Nil Nil Tower/Block Detail:-		Nil	Nil			,	
Tower No. / Name	/ Floor Area (Ground Coverage)		Overall Height	Occupied Height	Stair Case		
		Floor			Min As per NBC	As per Travel Distance	Provid e
Block 1	1114.29 SQM	Ground Floor	3.65 Mtrs	3.65 Mtrs	-		-
Block2 -	543.19 SQM	Ground Floòr	4.14 Mtrs	4.14 Mtrs			
Block 3	285.53 SQM	Ground Floor	3.65 Mtrs	3.65 Mtrs			
lock 4 Harvana	71.69 SQM	Ground Floor	3.65 Mtrš	3.65 Mtrs			

Nil

15/04/2024 Fire Fighting System Details:-

storate of Fin

No. 55-58.

Sr. No.	Norms as per NBC, 2016	Required	Proposed provisions	
1. Fire Extinguishers		Required	Proposed	
2.	Hose Reel	Required	Proposed	
3.	Dry Riser	N/R (Not Required)	N/P (Not Proposed)	
I	Wet Riser	N/R	N/P	

Government of Haryana "बेटी बचाओ-बेटी पढ़ाओ"